



PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, PANCHKULA

Website: <https://phedharyana.gov.in>

Memo No. -

Date: -

Subject : **Bacteriological Examination Report of Water Sample**

Sample ID:	PKL/02253/8/2026	Sample Details	Date & Time
Sample Classification:	Private	Collected By	Neha Kapoor, 9034125624
Sender:	Neha Kaooor	Collection Date	25/08/2026 at 11:23
Location :-	, Good Shepherd School, Vill - Nagal Bhaga, Kalka	Received at lab	25/08/2026 at 11:29
Latitude :-	76.915355	Tested at Lab	27/08/2026
Longitude :-	30.854375		

Test Result (As Per BIS 10500 :2012)


S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221 B & C

Remarks :-

- * The Results Given above are related to the sample as received and tested in PANCHKULA lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters, the water sample is found "**POTABLE**"




SONIA, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY PANCHKULA
email: -chemist.panchkula@phedharyana.gov.in

-----End of Report-----.